



Amuco Inc.

CERTIFICATE OF ANALYSIS

DATE : JAN.26,2014
ORDER NO. : 7-57859
PRODUCT : REFRIGERANT R407C
QUANTITY : 1,130.00KGS (100CYLINDERS X 11.3KG/CYLINDER)
MANUFACTURE DATE : JAN.20, 2014
EXPIRY DATE : JAN.20, 2016
BATCH NO. : 20140120
STANDARD : ARI700-2012

ITEMS	SPECIFICATIONS	RESULTS
APPEARANCE	COLORLESS & TRANSPARENT	COLORLESS & TRANSPARENT
ODOR	NO BAD SMELL	NO BAD SMELL
PURITY %	≥ 99.5	99.9
MOISTURE,PPM	≤ 10	9
ACIDITY (as HCL) PPM	≤ 1.0	<1
RESIDUE PPM	≤ 100	<40
CONCLUSION	UP TO STANDARD	